WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 71823
Permit No.
Basin 212

NOTICE OF INTENT NO. 17445

1. OWNER Southland Corporation
MAILING ADDRESS 555 South Renton Village #700 Renton, WA 98055
ADDRESS AT WELL LOCATION 1215 East Stewart Avenue Las Vegas, Nevada Clark County

2. LOCATION NW ¼ SW ¼ Sec. 35 T. 20 N/S R. 61 E/W
PERMIT NO. (Issued by Water Resources) 139-35-211-092 (Parcel No.) SOUTHLAND (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
4" Asphalt underlain by ABC gravel w/ silty sand, sand w/ silt light brown, color change to grayish orange pink.		0	6	
Clayey sand w/ trace gravels very pale orange, very stiff		6	10	
Poorly graded sand w/ little gravel, wet moderate yellowish brown - fine sand		10	16	
Fine sand w/ some silt, wet, pale yellowish brown, base increasing clay		16	20	
Caliche encountered @ 19' bgs highly cemented, very pale orange				

Date started 5-27, 1998
Date completed 5-27, 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 20 Feet Depth Cased 5 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
8	0	20

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"			0	5

Perforations:
Type perforation Sch 40
Size perforation .020
From 5 feet to 20 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 5
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 5 feet to 20 feet

9. WATER LEVEL
Static water level 10 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) THE VERDE COMPANIES, INC.
Address (Contractor) 3121 South Park Drive Tempe, Arizona 85282
Nevada contractor's license number issued by the State Contractor's Board 41809
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1112070
Signed (By driller performing actual drilling on site or contractor)
Date 6-26-98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627