WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 71824
Permit No.
Basin 212

NOTICE OF INTENT NO. 17415

1. OWNER SOUTHLAND CORPORATION
MAILING ADDRESS 355 SOUTH RENTON VILLAGE #700 RENTON, WA 98055
ADDRESS AT WELL LOCATION 1215 EAST STEWART AVENUE LAS VEGAS, NEVADA

2. LOCATION NW ¼ SW ¼ Sec. 35 T. 20 N/S R. 61 E. Clark County
PERMIT NO. (Issued by Water Resources) Parcel No. 139-35-211-012 Subdivision Name SOUTHLAND

3. WORK PERFORMED: ☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE: ☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE: ☐ Cable ☐ Rotary ☐ RVC ☐ Air ☒ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt underlain by fill consisting of silty sand w/ small gravels, light brown, poorly graded fine sand.		0	6	
Color change to yellowish gray less silt and sand		6	10	
greenish gray fine sand w/ clay and trace silt very moist trace gravels		10	16	
Silty sand w/ clay and trace gravel wet, yellowish gray, poorly graded caliche cobbles highly cemented		16	20	

Date started 5-27, 1998
Date completed 5-27, 1998

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 20 Feet Depth Cased 5 Feet

HOLE DIAMETER (BIT SIZE)
8 Inches From 0 Feet To 20 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"			0	5

Perforations:
Type perforation Sch 40
Size perforation .020
From 5 feet to 20 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 5
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 5 feet to 20 feet

9. WATER LEVEL
Static water level 10 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name THE VERDE COMPANIES, INC. (Contractor)
Address 3121 SOUTH PARK DRIVE (Contractor)
TEMPE, ARIZONA 85282
Nevada contractor's license number issued by the State Contractor's Board 41809
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M0070
Signed (By driller performing actual drilling on site or contractor)
Date 6-26-98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627