



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

*UBDA*

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37755

1. OWNER Brian Hewitt ADDRESS AT WELL LOCATION 1205 Serpentine Road  
 MAILING ADDRESS 1205 Serpentine Road Reno, Nevada 89506  
 2. LOCATION SW 1/4 SW 1/4 Sec. 14 T. 22 N. R. 19 E. EAST WASHOE County  
 PERMIT NO. 079-480-52 Red Rock Estates Subdivision Name #195 Res. C  
 Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fine brown sand		0	2	2
Brown Clay		2	5	3
Fine brown sand		5	16	11
Weathered granite		16	20	4
Weathered granite w/fine black sand		20	30	10
Weathered granite soft		30	45	15
Fractured weathered granite		45	100	55
Weathered granite w/brown sand	X	100	120	20
Weathered granite soft	X	120	125	5
Fractured black & white granite	X	125	160	35
T.D. 160'				

8. WELL CONSTRUCTION  
 Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10-5/8 Inches To 0 Feet 160 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8		.225	+1 1/2	160

Perforations:  
 Type perforation Factory Sawn  
 Size perforation 3/32 x 3  
 From 140 feet to 160 feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 160 feet to 50 feet

Date started May 18, 1998  
 Date completed May 19, 1998

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+		2 hrs

9. WATER LEVEL  
 Static water level 90 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.S.A.P. Pump & Well Service Inc. Contractor  
 Address P.O. Box 60130 Contractor  
Reno, Nevada 89506

Nevada contractor's license number issued by the State Contractor's Board 35387-A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2066

Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date May 24, 1998