WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 71943
Basin 71

NOTICE OF INTENT NO. 36088

1. OWNER Nash & Lynn Herrera
MAILING ADDRESS 8275 Stinson
Winnemucca, NV 89445

ADDRESS AT WELL LOCATION
7040 Torrey, Winnemucca

2. LOCATION NW 1/4 NW 1/4 Sec. 18 T 35N N/S R 38E E Humboldt County
PERMIT NO. _____ Issued by Water Resources | 10-611-06 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	2	2
Cobbles		2	133	131
Boulders		133	148	15
Cobbles & boulders		148	226	78

RECEIVED 98 MAY 27 AM 11:02 STATE ENGINEER'S OFFICE

Date started 5/14/98, 19__
Date completed 5/15/98, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		2 hrs.

8. WELL CONSTRUCTION
Depth Drilled 226 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 7/8 Inches		0 Feet	226 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	220

Perforations:
Type perforation Single row mill slot
Size perforation 1/8 x 3
From 180 feet to 220 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 65
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 65 feet to 226 feet

9. WATER LEVEL
Static water level 131 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc. (Contractor)
Address 4675 W. Winnemucca Blvd (Contractor)
Winnemucca, NV 89445

Nevada contractor's license number issued by the State Contractor's Board 015234

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2019

Signed [signature] By driller performing actual drilling on-site or contractor
Date 5-22-98