WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 71849
Permit No.
Basin 212

NOTICE OF INTENT NO. 17467

1. OWNER BOB DeNINNO C/O Southland
MAILING ADDRESS 555 S. RENTON Village #700 RENTON WASHINGTON 98005
ADDRESS AT WELL LOCATION 4581 E. CHARLESTON, Las Vegas, Boulevard

2. LOCATION NW ¼ NE ¼ Sec. 5 T. 21 ~~N~~/S R. 62 ~~E~~ Clark County
PERMIT NO. Issued by Water Resources | 161-05-102-004 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Coll Asphalt underlain		0	6	
by silty gravel w/				
coarse sand, moist				
moderate yellowish				
brown, sandy clay				
w/ some gravel,				
moist, some color				
Coarse sandy clay		6	11	
w/ few gravels, very				
moist, moderate				
yellowish brown,				
sandy clay w/ some		11	15	
well graded sand				

Date started 6-22, 1998
Date completed 6-22, 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 15 Feet Depth Cased 4 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
12	0	15

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4			0	4

Perforations:
Type perforation Sch 40
Size perforation .020
From 4 feet to 15 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 3
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 5 feet to 15 feet

9. WATER LEVEL
Static water level 5 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name The Verde Companies, Inc. Contractor
Address 3121 South Park Drive Contractor
Tempe, Arizona 85282
Nevada contractor's license number issued by the State Contractor's Board 41809
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2070
Signed John Manley
By driller performing actual drilling on site or contractor
Date 8-26-98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627