

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **15611**

1. OWNER Southwest Communities ADDRESS AT WELL LOCATION Aspen Peak Loop @ Red Bark Lane
 MAILING ADDRESS 500 N. Rainbow #314 LU NV 89107
 2. LOCATION NE 1/4 SE 1/4 Sec 35 T. 21 N/S R. 62 E. Clark County
 PERMIT NO. 161-35-713-077 South Valley Ranch Subdivision Name
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG MW-6

Material	Water Strata	From	To	Thick-ness
Fill - Sidewalk <u>cont type #</u>		0	2	
CALICHE		2	4	
SANDY GRAVEL		4	7	
CALICHE		7	10	
SANDY GRAVEL		10	11.5	
CALICHE		11.5	16.5	
SANDY CLAY - red		16.5	18	
/				

8. WELL CONSTRUCTION
 Depth Drilled 18 Feet Depth Cased 17.5 Feet
 HOLE DIAMETER (BIT SIZE)
5 1/8 Inches From 0 Feet To 18 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	PVC	sch 40	0	17.5

 Perforations:
 Type perforation slotted screen
 Size perforation .010 inch
 From 2.5 feet to 17.5 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 2.5 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 2.5 feet to 18 feet
 9. WATER LEVEL
 Static water level 8.95 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 6/24 1998
 Date completed 6/24 1998

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>N/A</u>		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Tim Allen c/o Terracon Thomas Beall Contractor
 Address 4343 S. Polaris Contractor
LU NV 89103
 Nevada contractor's license number issued by the State Contractor's Board _____
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 11944
 Signed Thomas H. Beall
 By driller performing actual drilling on site or contractor
 Date 7/2/98