WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 71860
Permit No.
Basin 218

NOTICE OF INTENT NO. 17443

1. OWNER Glendale Service Inc.
MAILING ADDRESS 2300 Glendale Blvd Glendale, Arizona
ADDRESS AT WELL LOCATION 2300 Glendale Boulevard Glendale, ~~Arizona~~ Nevada

2. LOCATION ¼ NE ¼ Sec. 2 T. 15 ~~N~~S R. 66 E. Clark County
PERMIT NO. M0-2586A Issued by Water Resources
MW4-690-170-014/MW5-690-170-010 Parcel No.
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Dirty clay & hard moist to dry		0	6	
Clay, dark, moist gravel		6	11	
Silty gravel reddish-yellow gravel, graded		11	18	
compacted silt layer				
wet pool				
Silty sand & clay w/ gravel, dark brown, wet, firm		18	23	

Date started 5/19, 1998
Date completed 5/19, 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 25.5 Feet Depth Cased 5 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	25.5 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"			0	5

Perforations:
Type perforation Sch 40
Size perforation .010
From 5 feet to 20 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 5
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 10 feet to 20 feet

9. WATER LEVEL
Static water level 16 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name THE VERDE COMPANIES, INC. Contractor
Address 3121 SOUTH PARK DRIVE Contractor
TEMPE, ARIZONA 85282
Nevada contractor's license number issued by the State Contractor's Board 0041809
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2010
Signed [signature] By driller performing actual drilling on site or contractor
Date 6-26-98

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627