

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 71820
 Permit No. _____
 Basin 71
 NOTICE OF INTENT NO. 35052

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Weryn Randall ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 6665 Germain
Winnemucca, NV 89445

2. LOCATION SW 1/4 1/4 Sec. 7 T 35N N/S R 38E E Humboldt County
 PERMIT NO. 10-483-01 Parcel No. _____ Subdivision Name _____
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	6	6
Sand & gravel		6	11	5
Rock up to 1/2"		11	21	10
Rock up to 1/4"		21	24	3
Sand & gravel		24	38	14
Coarse sand & gravel 3/8"		38	62	24
See next line		62	73	11
Coarse sand, small gravel w/little clay				
Coarse sand w/gravel		73	86	13
See next line		86	115	29
Sandy gravel w/sandy brown clay				
Brown clay w/gravel		115	124	9
Sand & gravel		124	127	3
See next line		127	173	46
Brown clay w/coarse sand & gravel up to 1/4"				
Sand & gravel		173	196	23
Coarse sand & gravel		196	220	25

8. WELL CONSTRUCTION
 Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)
 From _____ To _____
12 1/4 Inches 0 Feet 220 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8		5/16	+2	220

Perforations:
 Type perforation Mill slot
 Size perforation 1/8 x 3
 From 180 feet to 220 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 220 feet

Date started 4/22/98, 19____
 Date completed 4/24/98, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30</u>		<u>2.5 hrs.</u>

9. WATER LEVEL
 Static water level 135 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Humboldt Drilling & Pump Co., Inc. Contractor
 Address 4675 W. Winnemucca Blvd Contractor
Winnemucca, NV 89445
 Nevada contractor's license number issued by the State Contractor's Board 015234
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2099
 Signed Jerry G. Tomp
 By driller performing actual drilling on-site or contractor
 Date 5-7-98

RECEIVED
 MAY - 8 AM 10:36
 STATE ENGINEERING OFFICE