WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

**PRINT OR TYPE ONLY**
**DO NOT WRITE ON BACK**

# STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 71884
Permit No. 48

NOTICE OF INTENT NO. 39165

1. OWNER HENRY FOLLMAN
MAILING ADDRESS P.O. BOX 6411
ELKO, NV 89802

ADDRESS AT WELL LOCATION
NE CORNER OF STILWELL AVE & SO. 3RD ST.

2. LOCATION NW 1/4 SE 1/4 Sec. 23 T 32N N/S R 55E E ELKO County
PERMIT NO. (Issued by Water Resources) 27-043-006 (Parcel No.) LUCKY NUGGET #1 (Subdivision Name)

**3. WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

**4. PROPOSED USE**
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

**5. WELL TYPE**
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

**6. LITHOLOGIC LOG**

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| TOPSOIL | | 0 | 3 | 3 |
| CEMENTED BOULDERS & GRAVEL | | 3 | 80 | 77 |
| SILTSTONE & GRAVEL | X | 80 | 180 | 100 |

RECEIVED
98 JUL -6 AM 11:19
STATE ENGINEER'S OFFICE

Date started 5/29/98, 19__
Date completed 5/29/98, 19__

**7. WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 25 | | 3 |

**8. WELL CONSTRUCTION**
Depth Drilled 180 Feet Depth Cased 180 Feet

**HOLE DIAMETER (BIT SIZE)**

| | | From | To |
|---|---|---|---|
| 10 5/8 | Inches | 0 Feet | 180 Feet |
| | Inches | Feet | Feet |
| | Inches | Feet | Feet |

**CASING SCHEDULE**

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 13 | .188 | +1 | 180 |
| | | | | |

**Perforations:**
Type perforation MILLSLOT
Size perforation 3/16 X 3
From 160 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 180 feet

**9. WATER LEVEL**
Static water level 95 feet below land surfac
Artesian flow G.P.M. P.S.I
Water temperature °F Quality

**10. DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Hackworth Drilling, Inc. (Contractor)
Address P.O. Box 850 (Contractor)
Elko, NV 89803

Nevada contractor's license number issued by the State Contractor's Board 020582

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689

Signed Dave Hess
By driller performing actual drilling on-site or contractor

Date