WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 71888
Permit No. 75847
Basin 45

NOTICE OF INTENT NO. 39175

1. OWNER MAX CHRISTIANSEN Anthony Buettner
MAILING ADDRESS 8680 W. WASBURN ROAD
LAS VEGAS, NV 89129-4024

ADDRESS AT WELL LOCATION 1428 Penny Lane
BEHIND OLD LAMOILLE LANDFILL

2. LOCATION SW NW 1/4 NE 1/4 Sec. 24 T 33N N/S R 57E E ELKO County
PERMIT NO. 75847 Issued by Water Resources
006-52B-017 Parcel No.
TRACT OF LAND Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] ~~Domestic~~ [X] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOPSOIL		0	3	3
BROWN CLAY		3	5	2
BOULDERS & GRAVEL		5	60	55
SAND & GRAVEL	X	60	180	120

98 JUL -6 AM 11:19
STATE ENGINEER'S OFFICE

Date started 6/24/98 , 19__
Date completed 6/24/98 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50		3

NAD 27
40.736665°N
115.494229°W

8. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8	Inches	0 Feet	180 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1	180

Perforations:
Type perforation MILLSLOT
Size perforation 3/16 X 3
From 160 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 180 feet

9. WATER LEVEL
Static water level 91 feet below land surfac
Artesian flow G.P.M. P.S.I
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Hackworth Drilling, Inc. Contractor
Address P.O. Box 850 Contractor
Elko, NV 89803

Nevada contractor's license number issued by the State Contractor's Board 020582

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689

Signed [signature] By driller performing actual drilling on-site or contractor
Date 7-2-98