

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 71901
 Permit No. _____
 Basin 103

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 38826

1. OWNER Michael Walter Construction ADDRESS AT WELL LOCATION 110 Nugget
 MAILING ADDRESS 3 Malachite Rd Dayton W.
Yerington NV 89447
 2. LOCATION SE 1/4 SW 1/4 Sec. 9 T. 17 N/S R. 22 E. Lyon County
 PERMIT NO. 19-162-07 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Blow Sands</u>		<u>0</u>	<u>3</u>	<u>3</u>
<u>Hard Pan Sands</u>		<u>3</u>	<u>17</u>	<u>14</u>
<u>DT Sands</u>		<u>17</u>	<u>48</u>	<u>31</u>
<u>Obsidian Sands Clay Seams</u>		<u>48</u>	<u>110</u>	<u>62</u>
<u>Brown Clay</u>		<u>110</u>	<u>163</u>	<u>53</u>
<u>Brown Clay Strates</u>		<u>163</u>	<u>194</u>	<u>31</u>
<u>Small Sands</u>				
<u>Fractured Volcanic</u>	<u>XXX</u>	<u>194</u>	<u>210</u>	<u>16</u>
<u>Gravels</u>				

8. WELL CONSTRUCTION
 Depth Drilled 210 Feet Depth Cased 210 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To
<u>1.031/4</u>	<u>0</u>	<u>210</u>
_____	_____	_____
_____	_____	_____

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.5/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>210</u>
_____	_____	_____	_____	_____

Perforations:
 Type perforation Mill Slot
 Size perforation 3x3/32
 From 190 feet to 210 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 55
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 55 feet to 210 feet

9. WATER LEVEL
 Static water level 70 feet below land surface
 Artesian flow _____ G.P.M. 30 P.S.I.
 Water temperature Cold °F Quality Good

Date started 4-16, 1998
 Date completed 4-8, 1998

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30</u>	<u>69</u>	<u>3 HRS</u>
_____	_____	_____	_____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Capital City Well Drilling Contractor
 Address 20 Kit Kat Dr Contractor
Carson City NV 89706
 Nevada contractor's license number issued by the State Contractor's Board 0041775
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1205
 Signed Michael Mack
 By driller performing actual drilling on site or contractor
 Date 7-9-98

RECEIVED
 98 JUL 14 AM 8:10
 STATE ENGINEERS OFFICE



[Faint, mostly illegible handwriting on lined paper. The text appears to be a list or ledger with multiple columns and rows. Some words like 'DATE', 'DESCRIPTION', and 'AMOUNT' are faintly visible.]

[Vertical stamp or text on the right side of the page, possibly a date or reference number.]



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 71901
 Permit No. 103
 Basin 103

NOTICE OF INTENT NO. 38826

1. OWNER Michael Walter Construction ADDRESS AT WELL LOCATION 110 Nugget Dayton NV
 MAILING ADDRESS 3 Malachite Rd Yerington NV 89447

2. LOCATION SE 1/4 S6W 1/4 Sec 9 T 17 R 22 E Lyon County
 PERMIT NO. 19-162-07 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Hand

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Blow Sands		0	3	3
Hard Pan Sands		3	17	14
DB Sands		17	48	31
Obsidian Sands Clay Seams		48	110	62
Brown Clay		110	163	53
Brown Clay Strata		163	194	31
Small Sands				
Fractured Volcanic	XXX	194	210	16
Gravels				

8. WELL CONSTRUCTION
 Depth Drilled 210 Feet Depth Cased 210 Feet

HOLE DIAMETER (BIT SIZE)
 From 103/4 Inches To 0 Feet 210 Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>65/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>210</u>

Perforations:
 Type perforation Mill Slot
 Size perforation 3x3/32
 From 190 feet to 210 feet
 From feet to feet
 From feet to feet
 From feet to feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 55
 Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 55 feet to 210 feet

Date started 4-10 1998
 Date completed 4-9 1998

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	<input checked="" type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>30</u>	<u>6.9</u>	<u>3 HRS</u>	

9. WATER LEVEL
 Static water level 70 feet below land surface
 Artesian flow 30 G.P.M. P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Capital City Well Drilling Contractor
 Address 20 Kit Kat Dr Carson City NV 89706 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 0041775
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1205
 Signed Michael Black
 By driller performing actual drilling on site or contractor
 Date 7-9-98

RECEIVED
 28 JUL 16 AM 8:10
 STATE ENGINEERS OFFICE