WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. X1904
Permit No.
Basin 94

NOTICE OF INTENT NO. 37849

1. OWNER PETE & CHRISTINE CAMPANA
MAILING ADDRESS 15110 Gooding Drive
Reno, Nevada 89506

ADDRESS AT WELL LOCATION
15110 Gooding Drive
Reno, Nevada 89506

2. LOCATION NW SE ¼ NW SW ¼ Sec. 8 5 T. 22N N/S R. 19 E. Washoe County
PERMIT NO. (Issued by Water Resources) 079-382-79 (Parcel No.) Red Rock Estates #91 parcel 3 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	3	3
Brown sandy clay		3	16	13
Sand & gravel		16	18	2
Brown sandy clay		18	66	48
Brown sand		66	69	3
Brown sandy clay		69	106	37
Green sandy clay		106	130	24
Gray sansy clay		130	166	36
Dark gray sandy clay		166	216	50
Soft zone	X	216	240	24
Dark gray sandy clay		240	245	5

Date started 6-3-98, 19
Date completed 6-4-98, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10		

8. WELL CONSTRUCTION
Depth Drilled 245 Feet Depth Cased 245 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	50 Feet	
8 5/8 Inches	50 Feet	245 Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	245

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 205 feet to 245 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 feet
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 245 feet

9. WATER LEVEL
Static water level 185 feet below land surface
Artesian flow G.P.M. 10 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 0022549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date June 5, 1998

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627