WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 71908
Permit No.
Basin 33B
NOTICE OF INTENT NO. 36085

1. OWNER Eric Youngberg
MAILING ADDRESS HR 9
Orovada, NV 89425

ADDRESS AT WELL LOCATION
Flat Creek Ranch, Orovada, NV

2. LOCATION NE 1/4 NW 1/4 Sec. 33 T 45N N/S R 38E E Humboldt County
PERMIT NO. ____ Issued by Water Resources | 3-271-14 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other ____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other ____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy clay		0	2	2
Cobbles		2	132	130
Clay		132	144	12
Cobbles & boulders		144	246	102

RECEIVED
98 JUN -5 PM 12:26
STATE ENGINEER'S OFFICE

Date started 5/10/98, 19__
Date completed 5/10/98, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
8		3 hrs.

8. WELL CONSTRUCTION
Depth Drilled 246 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	246	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	240

Perforations:
Type perforation Single row mill slot
Size perforation 1/8 x 3
From 180 feet to 240 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 246 feet

9. WATER LEVEL
Static water level 65 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc.
Contractor
Address 4675 W. Winnemucca Blvd
Contractor
Winnemucca, NV 89445

Nevada contractor's license number issued by the State Contractor's Board 015234

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2019

Signed Jerry L. Tompk
By driller performing actual drilling on-site or contractor

Date 6-4-98