WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

**PRINT OR TYPE ONLY**
**DO NOT WRITE ON BACK**

**STATE OF NEVADA**
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 71911
Permit No.
Basin 44

NOTICE OF INTENT NO. 39286

1. OWNER **CRAIG MAULDIN**
MAILING ADDRESS **RYNDON UNIT 186 BOX 13**
**ELKO, NV 89801**

ADDRESS AT WELL LOCATION
**SE CORNER AT HARRISON & SO 4TH ST.**
Elko, NV

2. LOCATION **SW** 1/4 **SW** 1/4 Sec. **5** T **35N** N/S R **57E** E **ELKO** County
PERMIT NO. _____ Issued by Water Resources
**26-021-004** Parcel No.
**TWIN RIVER RANCHO #4** Subdivision Name

**3. WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

**4. PROPOSED USE**
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

**5. WELL TYPE**
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

**6. LITHOLOGIC LOG**

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| TOPSOIL | | 0 | 3 | 3 |
| SILTSTONE | | 3 | 60 | 57 |
| SANDSTONE | X | 60 | 140 | 80 |

Date started **6/1/98**, 19__
Date completed **6/1/98**, 19__

**7. WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 25 | | 3 |

**8. WELL CONSTRUCTION**
Depth Drilled **140** Feet Depth Cased **140** Feet

**HOLE DIAMETER (BIT SIZE)**

| | | From | | To | |
|---|---|---|---|---|---|
| 10 5/8 | Inches | 0 | Feet | 140 | Feet |
| | Inches | | Feet | | Feet |
| | Inches | | Feet | | Feet |

**CASING SCHEDULE**

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 13 | .188 | +1 | 140 |
| | | | | |

**Perforations:**
Type perforation **MILLSLOT**
Size perforation **3/16 X 3**
From **120** feet to **140** feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal **50'**
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From **50** feet to **140** feet

**9. WATER LEVEL**
Static water level **91** feet below land surfac
Artesian flow _____ G.P.M. _____ P.S.I
Water temperature _____ °F Quality

**10. DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Hackworth Drilling, Inc.** Contractor
Address **P.O. Box 850** Contractor
**Elko, NV 89803**

Nevada contractor's license number issued by the State Contractor's Board **020582**

Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1689**

Signed [signature] By driller performing actual drilling on-site or contractor
Date 6-2-98