WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 7914
Permit No.
Basin 101

NOTICE OF INTENT NO. 39016

1. OWNER AKINS CONSTRUCTION
MAILING ADDRESS 2160 RICE ROAD
FALLON, NV 89406

ADDRESS AT WELL LOCATION
877 DRIFTWOOD DRIVE, Fallon NV

2. LOCATION SE 1/4 SE 1/4 Sec. 29 T 19 N/S R 28 E CHURCHILL County
PERMIT NO. _____ Issued by Water Resources
8-652-63 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN SAND		0	14	14
BROWN CLAY		14	17	3
BROWN SAND		17	28	11
GREY SAND		28	40	12
BLACK SILT		40	54	14
GREY SAND		54	70	16
BLACK CLAY		70	72	2
BROWN GRAVEL/SAND	X	72	85	13

RECEIVED 98 MAY 11 AM 10:27 STATE ENGINEER'S OFFICE

Date started 4/13/98 , 19__
Date completed 4/13/98 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40		1 hr.

8. WELL CONSTRUCTION
Depth Drilled 84 Feet Depth Cased 84 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/4	Inches	0	Feet	50	Feet
6 1/4	Inches	50	Feet	85	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+1	85

Perforations:
Type perforation MACHINE SLIT
Size perforation .080
From 79 feet to 84 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 12.3 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Welsco Drilling Corp. (Contractor)
Address 305 E. WILLIAMS AVE. P. O. BOX 888 (Contractor)
FALLON, NV 89407

Nevada contractor's license number issued by the State Contractor's Board 11752

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996

Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 4-30-98