WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 7917
Permit No. 102
Basin

NOTICE OF INTENT NO. 29656

1. OWNER Robert McKinnon
MAILING ADDRESS 1035 Munley
Reno, NV 89503

ADDRESS AT WELL LOCATION 9331 Via Catalina
Silver Springs, NV

2. LOCATION SE ¼ NW ¼ Sec. 25 T. 17 N/S R. 24 E. Lyon County
PERMIT NO. 17-535-06 (Issued by Water Resources) Parcel No.
Morningside (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| SAND | | 0 | 4 | 4 |
| Clay | | 4 | 55 | 51 |
| Sand | | 55 | 58 | 3 |
| Silt & Clay | | 58 | 80 | 22 |
| Clay | | 80 | 100 | 20 |
| Sand & Gravel | X | 100 | 121 | 21 |
| Clay | | 121 | | |

RECEIVED 98 JUN -9 PM 12:07 STATE ENGINEER'S OFFICE

Date started 5/1, 1998
Date completed 5/21, 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 25 | 0 | 4hrs |

8. WELL CONSTRUCTION
Depth Drilled 121 Feet Depth Cased 121 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 10 Inches | | 0 Feet | 52 Feet |
| 6 Inches | | 0 Feet | 121 Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 13.77 | .188 | 0 | 121 |

Perforations:
Type perforation machined
Size perforation 3x 1/8
From 121 feet to 111 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 52
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 48 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Vernon Cannon Jr. (Contractor)
Address 4555 Hwy 50 W (Contractor)
Silver Springs, NV 89429
Nevada contractor's license number issued by the State Contractor's Board 23317
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1455
Signed Vernon Cannon Jr. (By driller performing actual drilling on site or contractor)
Date 5/23/98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627