WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 11420
Permit No.
Basin 91

NOTICE OF INTENT NO. 37852

1. OWNER Jim Kuraisa
MAILING ADDRESS P.O. Box 267
Verdi, Nevada 89439

ADDRESS AT WELL LOCATION 2105 Warroir Lane
Verdi, Nevada 89439

2. LOCATION SE ¼ SE ¼ Sec. 16 T 19N N/S R 18 E Washoe County
PERMIT NO. (Issued by Water Resources) 038-132-04 (Parcel No.) Blue Heron (across from Boomtown) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill dirt & boulders		0	2	2
Brown clay		2	4	2
Brown sandy clay		4	11	7
Green sandy clay		11	16	5
Brown sandy clay		16	31	15
Gray sandy clay		31	41	10
Dark brown sandy clay		41	56	15
Soft zone	X	56	58	2
Dark brown clay		58	61	3
Gray clays		61	90	29
Black volcanic rock		90	101	11
Fracture	X	101	106	5
Black volcanic rock		106	120	14

Date started 7-13-98, 19
Date completed 7-16-98, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50+		

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
9 7/8 Inches	0 Feet	120 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	120

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100 feet
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 120 feet

9. WATER LEVEL
Static water level 17 feet below land surface
Artesian flow G.P.M. 50+ P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 0022549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date July 17, 1998

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627