



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 9878

1. OWNER Paula Smith ADDRESS AT WELL LOCATION 103 Merrel Ct
 MAILING ADDRESS 103 Merrel Ct Dayton NV
 2. LOCATION SW 1/4 SW 1/4 Sec. 5 T. 16 S R. 22 E Lyon County
 PERMIT NO. 19-654-02
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Course Sands		0	10	10
Brown Clay		10	36	26
Small Sand and Gravel		36	93	57
Brown Clay		93	110	7
Gray Volcanic Clay		110	149	39
Small Sands		149	168	19
Brown Clay Seams of Volcanic Sands		149	168	19
Volcanic Fragments	XX	168	180	12
Red & Black Rusky				

RECEIVED
 98 JUN -5 PM 12:56
 STATE ENGINEERING OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 3/4 Inches To 180 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.63</u>	<u>1.18</u>	<u>0</u>	<u>180</u>

Perforations:
 Type perforation Mill Slot
 Size perforation 3 x 3/32
 From 160 feet to 180 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 58'
 Placement Method: Pumped Poured
 Concrete Grout

Gravel Packed: Yes No
 From 58' feet to 180' feet

9. WATER LEVEL
 Static water level 75 feet below land surface
 Artesian flow _____ G.P.M. 30 P.S.I.
 Water temperature Warm °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Capital City Well Drilling
 Address 20 1st Kat DR Carson City NV 89204
 Nevada contractor's license number issued by the State Contractor's Board 41775
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
 Signed Michael L. Hock
 By driller performing actual drilling on site or contractor
 Date 6-2-98

Date started 5-30 1998
 Date completed 6-2 1998

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30</u>	<u>60</u>	<u>3 HRS</u>