

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Office use only
Log No. 7931
Permit No.
Basin 7e
NOTICE OF INTENT NO **38292**
690 Stock Lane

1. OWNER **Susan Kelton**
MAILING ADDRESS **690 Stock Lane**
Fernley, NV

ADDRESS AT WELL LOCATION

2. Location **SW 1/4 SW 1/4 Sec 14 T 20N R 24E** **Lyon** County
PERMIT NO. **PARCEL NO. 021-141-29** SUBDIVISION NAME

3. WORK PERFORMED | 4. PROPOSED USE | 5. WELL TYPE
 New Well | Replace | Recondition | Domestic | Irrigation | Test | Cable | Rotary | RVC
 Deepen | Abandon | Other | Municipal/Industrial | Monitor | Stock | Air | Other | Mud

6. LITHOLOGIC LOG					8. WELL CONSTRUCTION					
Material	Water Strata	From	To	Thickness	Depth Drilled		Depth Cased		HOLE DIAMETER (BIT SIZE)	
Top soil.		0	10	10	10 5/8	inches	0	feet	150	feet
Brown sand.		10	30	20	6 1/8	inches	150	feet	250	feet
Gray sand.		30	40	10						
Brown sand.		40	55	15	6 5/8	12.94	188	+1 1/2	150	250
Gravel & sand.		55	160	105	5	6.58	188	150	250	
Fractured rock.		165	230	65	CASING SCHEDULE					
Brown clay,		230	250	20	Size O.D. Weight/Ft. Wall Thickness From To					
				0	(Inches) (Pounds) (Inches) (Feet) Feet					
				0	6 5/8 12.94 188 +1 1/2 150					
				0	5 6.58 188 150 250					
				0	Perforations:					
				0	Type Perforation	Factory				
				0	Size perforation	3/32 x 3"				
				0	From 130	feet to	150	feet		
				0	From 170	feet to	230	feet		
				0	From	feet to		feet		
				0	From	feet to		feet		
				0	From	feet to		feet		
				0	From	feet to		feet		
				0	Surface Seal	<input checked="" type="checkbox"/> YES	No	Seal Type:		
				0	Depth of Seal	100	feet	Neat Cement		
				0		<input checked="" type="checkbox"/> Pumped		<input checked="" type="checkbox"/> Cement Grout		
				0		Poured		Concrete Grout		
				0	Gravel Packed:	<input checked="" type="checkbox"/> Yes	No			
				0	From 100	feet to	150	feet		

RECEIVED
98 MAY 28 AM 10:02
STATE ENGINEERS OFFICE

Date started **4-8 -98**
Date completed **4-13 -98**

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	x	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (hours)		
6	225	4		

9. WATER LEVEL
 Static water level **25** feet below land surface
 Artesian flow **0** GPM **0** P.S.I.
 Water Temperature **cold** Degrees F Quality

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **McKay Drilling, Inc.**
2290 Pioneer Drive
Reno, NV 89509
 NV Contractors No. **14170**
 NV Driller's Lic (on site) **1261**
 Signed *[Signature]*
 By driller performing actual drilling on site or contractor
 Date **5-15-98**

I