



Log No. 71940  
 Permit No. \_\_\_\_\_  
 Basin 44

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36544

1. OWNER DLIC INC ADDRESS AT WELL LOCATION LA VISA DRIVE  
 MAILING ADDRESS P.O. Box 35  
ELKO, NV 89603

2. LOCATION SE 1/4 Sec 36 T 36 N 10 R 56 E County ELKO  
 PERMIT NO. CCC-3314-CBR Parcel No. \_\_\_\_\_ Subdivision Name RYNDON  
 Issued by Water Resources \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY LOAM		0	2	2
MUD SANDSTONE		3	17	15
CLAY		17	28	11
SANDSTONE		27	36	9
CLAY		36	42	6
SANDSTONE		42	100	58
CLAY		100	171	71
SAND + GRAVEL	X	171	172	1
CLAY		172	189	17
SAND + GRAVEL	X	189	192	3

8. WELL CONSTRUCTION

Depth Drilled 192 Feet Depth Cased 192 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
<u>10 7/8</u>	<u>0</u>	<u>171</u>		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>13.42</u>	<u>1.88</u>	<u>11</u>	<u>192</u>

Perforations:

Type perforation MUD SLOT  
 Size perforation 3 1/2" x 3"  
 From 171 feet to 192 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 50  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 192 feet

Date started 5-25, 1998  
 Date completed 5-26, 1998

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>HYDRO</u>	<u>30</u>		<u>4.5</u>

9. WATER LEVEL

Static water level 110 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 100 °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name FERTIG DRILLING Contractor  
 Address P.O. Box 535 Contractor  
ELKO, NV 89603

Nevada contractor's license number issued by the State Contractor's Board 2031907  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1574

Signed Shane Fertig  
 By driller performing actual drilling on site or contractor  
 Date 5-26-98