



Log No. 71943
 Permit No. _____
 Basin 137B

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32235

1. OWNER JOHN N. LACEY ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS PO BOX 1064 MUSTANG COURT
ROUND MTN NEVADA 89045
 2. LOCATION S.W. 1/4 NE 1/4 Sec 4 T. 10 N/S R. 43 E. NYE County
 PERMIT NO. 12-461-57 Issued by Water Resources Parcel No. _____ Subdivision Name SENITA COURTS

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN CLAY		0	12	12
SMALL GRAVEL		12	14	2
BKN CLAY		14	18	4
SMALL GRAVEL & SAND		18	23	5
GRAY CLAY		23	26	3
COARSE SAND		26	36	10
TAN CLAY		36	48	12
SMALL GRAVEL & SAND		48	62	14
BROWN CLAY		62	64	2
BK GRAVEL	X	64	80	16
TAN CLAY		80	93	13
FINE SAND		93	105	12
BROWN CLAY		105	108	3
MED TO BK GRAVEL	X	108	130	22
DARK BROWN CLAY		130	145	15
BOULDERS & BK GRAVEL	X	145	158	13
BROWN CLAY		158	160	2

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 Inches 0 Feet 50 Feet
8 3/4 Inches 50 Feet 160 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.9</u>	<u>.188</u>	<u>7.2</u>	<u>160</u>

Perforations:
 Type perforation MILLED
 Size perforation 3 1/2 QUALIFIED ROW
 From 120 feet to 130 feet
 From 150 feet to 150 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
X ENVIRO PLUB
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 10 feet below land surface
 Artesian flow NO G.P.M. _____ P.S.I. _____
 Water temperature 60 °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WOYTEK DRILLING CO. INC. Contractor

Date started 5-11, 1998
 Date completed 5-11, 1998

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>100</u>		<u>3 HRS</u>

Address 2220 STONE DR Contractor
RENO NEV 89511
 Nevada contractor's license number issued by the State Contractor's Board 024521A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442
 Signed Thomas M. Harris
 By driller performing actual drilling on site or contractor
 Date 5-12-98