

OFFICE USE ONLY
 Log No. 71947
 Permit No. 212
 Basin 212

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16662

1. OWNER Las Vegas Paiutes Tribe ADDRESS AT WELL LOCATION Snow Mountain
 MAILING ADDRESS 1 Paiute Drive Mountain Reservation
Las Vegas, NV 89106

2. LOCATION NE 1/4 NE 1/4 Sec. 25 T. 18 N/S R. 59 E Clark County

PERMIT NO. R-1019 Issued by Water Resources Parcel No. 540-200-12 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Fill gravel, boulders		1	20	20
Black & gray rock		20	90	70
Brown clay		90	95	5
Mixed black & gray rock		95	110	15
Brown clay		110	295	185
Brown clay mixed w/ black & gray rock		225	310	15
Black & gray & quartz rock mixed w/red clay		310	340	30
Bentonite seal placed:		100	103	
		150	153	

8. WELL CONSTRUCTION
 Depth Drilled 340 Feet Depth Cased 230 Feet

HOLE DIAMETER (BIT SIZE)
 From 1.0 Inches To 340 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"		Sch. 40	1	230

Perforations: slotted screen
 Type perforation _____
 Size perforation 020
 From 201 feet to 230 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 230 feet

Date started July 5, 1998
 Date completed July 22, 1998

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
 Static water level 211 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Thompson Drilling Co., Inc.
 Address 7227 Hauck Street
Las Vegas, NV 89118

Nevada contractor's license number 4286A
 issued by the State Contractor's Board

Nevada driller's license number issued by the 2010
 Division of Water Resources, the on-site driller

Signed Richard K. Thompson
 By driller performing actual drilling on site or contractor

Date July 23, 1998