



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 14897

1. OWNER Henry P. Kinghorn ADDRESS AT WELL LOCATION: Vacant
 MAILING ADDRESS: 7135 REBECCA RD
 2. LOCATION NW 1/4 NW 1/4 Sec. 23 T 19S N/S R 60 E Clark County
 PERMIT NO. 125-23-101-003 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED: New Well Replace Recondition Deepen Abandon Other
 4. PROPOSED USE: Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE: Cable Rotary RVC Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Popcorn Caliche		0	35	
Bentanite Clay		35	60	
Clay		60	120	
Hard Limestone		120	130	
Clay		130	160	
Clay & Water	xx	160	170	
Clay		170	360	
Clay & Water	xx	360	390	
Clay		390	505	
Hard Limesone & Water		505	570	

8. WELL CONSTRUCTION
 Depth Drilled 570 Feet Depth Cased 570 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 Feet To 570 Feet
12 1/4 Inches
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	+1	570

Perforations:
 Type perforation Factory
 Size perforation 3/16 x 8 row
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 200 Cement Grout
 Placement Method: Pumped Poured Concrete Grout
 Gravel Packed: Yes No
 From 200 feet to 570 feet

9. WATER LEVEL
 Static water level 121 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality _____

Date started 6/21/98, 19____
 Date completed 7/6/98, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Vernon H. Dimick Contractor
 Address 5360 Bonita Vista
Las Vegas, Nev. 89129
 Nevada contractor's license number 10062 issued by the State Contractor's Board
 Nevada driller's license number issued by the 552 Division of Water Resources, the on-site driller
 Signed V.A. Dimick
 By driller performing actual drilling on site or contractor
 Date 7-6-98

