WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 71964
Perm. No.
Basin 102

NOTICE OF INTENT NO. 35176

1. OWNER Richard Zimbaro
MAILING ADDRESS 7100 Beach Rd
Silver Springs NV 89429
ADDRESS AT WELL LOCATION 7100 Beach Silver Springs

2. LOCATION NW ¼ NW ¼ Sec. 13 T. 17 N/S R. 24 E. County
PERMIT NO. Issued by Water Resources
17-233-02 Parcel No.
Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Boulders | | 200 | 210 | 10 |
| Bedrock | | 210 | 260 | 50 |

RECEIVED 98 JUN 10 AM 10:00 STATE ENGINEER'S OFFICE

Date started 5/18/98, 19
Date completed 5/22/98, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 2 gpm | | 5 hrs |

8. WELL CONSTRUCTION
Depth Drilled 60 Feet Depth Cased 80 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 7 7/8 Inches | 200 Feet | 260 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 1.88 | .13 | 180 | 260 |
| | | | | |

Perforations:
Type perforation Torch
Size perforation ½ x 2 x 4#
From 200 feet to 260 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 155 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature C °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Green Drilling Inc (Contractor)
Address P.O. 599 (Contractor)
S.S. NV 89429
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876
Signed (By driller performing actual drilling on site or contractor)
Date 6/9/98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627