

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 71966  
 Permit No. \_\_\_\_\_  
 Basin 101  
 NOTICE OF INTENT NO. 37726

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Bob Hyde ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 4940 Silver Sage lane 4940 Silver Sage Lane, Fallon, NV 89406  
 Fallon, NV 89406

2. LOCATION SE 1/4 SW 1/4 Sec. 18 T 18N N/S R 29E E Churchill County  
 PERMIT NO. 006-811-67 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	8	8
Brown Clay		8	11	3
Fine Coarse Sand		11	16	5
Brown Clay		16	28	12
Fine Brown Sand		28	30	2
Fine & Coarse Brown Sand		30	36	6
Fine Green Sand		36	44	8
Black Silty Clay		44	52	8
Gray Silty Clay		52	78	26
Coarse Black Sand		78	85	7
Black Silty Clay		85	93	8
Green Coarse Sand		93	106	13
Fine Green Sand		106	111	5
Brown Clay		111	138	27
Brown Coarse Sand	X	138	148	10

8. WELL CONSTRUCTION  
 Depth Drilled 148 Feet Depth Cased 148 Feet

HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
10 Inches 0 Feet 148 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	14.96	.188	0	10
6 PVC	3.92	.258	0	148

Perforations:  
 Type perforation Saw Cut  
 Size perforation 1/8  
 From 142 feet to 145 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 148 feet

9. WATER LEVEL  
 Static water level 12 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. Contractor  
 Address P.O. Box 1265 Contractor  
Fallon, NV 89407-1265  
 Nevada contractor's license number issued by the State Contractor's Board 29064  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715  
 Signed Douglas Parson  
 By driller performing actual drilling on-site or contractor  
 Date 6-10-98

Date started 5/21/98, 19\_\_\_\_  
 Date completed 5/21/98, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20</u>		<u>1 hr.</u>