

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 71976
 Permit No. _____
 Basin 179

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33067
 SMITH VALLEY (6 miles North of Ely)

1. OWNER Jeff Bell ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P.O. Box 150503 _____
East Ely, NV 89315-0503 _____
 2. LOCATION SW 1/4 NW 1/4 Sec 8 T 17 N 63 E White Pine County
 PERMIT NO. 16 APN 5610-18
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	5	5
Clay & Gravel		5	20	15
Gravel & Sand		20	30	10
Gravel & Clay		30	55	25
Water Bearing Sand & Gravel	x	55	75	20
Clay Some Gravel & Sand		75	100	25
Water Bearing Gravel & Sand	x	100	120	20
Clay Some Gravel & Sand		120	160	40

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 160 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	160

Perforations: Factory
 Type perforation _____
 Size perforation 1 7/8" x 2 1/4" 6 ROWS
 From 60 feet to 160 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 _____
 Neat Cement
 Cement Grout
 Concrete Grout
 Placement Method: Pumped
 Poured
 Gravel Packed: Yes No
 From 50 feet to 160 feet

9. WATER LEVEL
 Static water level 12 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Christiansen Drilling, Inc.
 Contractor
 Address 557 Ely Avenue
 Contractor
Ely, NV 89301
 Nevada contractor's license number issued by the State Contractor's Board 14790
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1793
 Signed Rich Lewis By Donald D. Christiansen
 By driller performing actual drilling on site or contractor
 Date April 29, 1998

Date started April 21, 1998
 Date completed April 23, 1998

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
90	138	1 1/2

RECEIVED
 98 MAY - 1 AM 10:48
 STATE ENGINEERS OFFICE