

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Edg. No. 71995
 Permit No. _____
 Basin 57
 NOTICE OF INTENT NO. 37720

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Alex Vanderstoal ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS HC61 Box 195 Antelope Valley Road
Battle Mtn, NV 89820 Near Dimas Farms

2. LOCATION SW 1/4 NW 1/4 Sec. 6 T 24N N/S R 41E E Lander County
 PERMIT NO. _____ Issued by Water Resources _____ Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---------------|--------------|------|-----|-----------|
| Gravel | | 0 | 17 | 17 |
| Brown Clay | | 17 | 28 | 11 |
| Coarse Gravel | | 28 | 34 | 6 |
| Brown Clay | | 34 | 40 | 6 |
| Coarse Gravel | | 40 | 60 | 20 |
| Brown Clay | | 60 | 74 | 14 |
| Coarse Gravel | | 74 | 87 | 13 |
| Brown Clay | | 87 | 99 | 12 |
| Coarse Gravel | | 99 | 113 | 14 |
| Brown Clay | | 113 | 121 | 8 |
| Coarse Gravel | | 121 | 127 | 6 |
| Brown Clay | | 127 | 137 | 10 |
| Coarse Gravel | | 137 | 143 | 6 |
| Brown Clay | | 143 | 164 | 21 |
| Coarse Gravel | | 164 | 188 | 24 |
| Brown Clay | | 188 | 200 | 12 |
| Sand & Gravel | | 200 | 213 | 13 |
| Brown Clay | | 213 | 222 | 9 |
| Coarse Gravel | | 222 | 234 | 12 |
| Brown Clay | | 234 | 245 | 11 |
| Coarse Gravel | X | 245 | 268 | 23 |

8. WELL CONSTRUCTION
 Depth Drilled 268 Feet Depth Cased 268 Feet

HOLE DIAMETER (BIT SIZE)
 From _____ To _____
10 Inches 0 Feet 268 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 8 5/8 | 14.96 | .188 | 0 | 10 |
| 6 PVC | 3.92 | .258 | 0 | 268 |

Perforations:
 Type perforation Saw Cut
 Size perforation 1/8
 From 228 feet to 268 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50
 Placement Method: Pumped Poured
 Poured

Gravel Packed: Yes No
 From 50 feet to 268 feet

9. WATER LEVEL
 Static water level 110 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cool °F Quality Unknown

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Parsons Drilling, Inc. Contractor
 Address P.O. Box 1265 Contractor
Fallon, NV 89407-1265
 Nevada contractor's license number issued by the State Contractor's Board 29064
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715
 Signed Douglas Parson
 By driller performing actual drilling on-site or contractor
 Date 5-11-98

Date started 4/16/98, 19____
 Date completed 4/16/98, 19____

7. WELL TEST DATA

| TEST METHOD: | Draw Down (Feet Below Static) | | Time (Hours) |
|-----------------------------------|-------------------------------|--|--------------|
| | G.P.M. | | |
| <input type="checkbox"/> Bailer | | | |
| <input type="checkbox"/> Pump | | | |
| <input type="checkbox"/> Air Lift | | | |