WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 71996
Permit No.
Basin 61

NOTICE OF INTENT NO. 37536

1. OWNER Barrick Goldstrike Mines, Inc.
MAILING ADDRESS P.O. Box 29
Elko, NV 89803

ADDRESS AT WELL LOCATION
Barrick Goldstrike Minesite
GWOP-8B

2. LOCATION NW ¼ NE ¼ Sec. 29 T. 36 N/S R. 50 E. Eureka County
PERMIT NO. n/a M10-220 Issued by Water Resources | n/a Parcel No. | n/a Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Clay w/gravel		0	35	35
Sandy Red Rock		35	100	65
Sandy Red/Brown Rock		100	150	50
*Sandy 3/4 Gravel	220	150	240	90
*poor circulation				
Bentonite Pellet Seal 185'-190'				
Pump Bentonite slurry 185-10'				

RECEIVED 98 APR -3 AM 10:43 STATE ENGINEER'S OFFICE

Date started March 17, 1998
Date completed March 18, 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
3		4½

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8½ Inches		0 Feet	240 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4½	pvc	Sch 80	0	240

Perforations:
Type perforation Mill Slot
Size perforation .020
From 215 feet to 235 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 10
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From XXX 190 feet to 240 feet

9. WATER LEVEL
Static water level 226 feet below land surface
Artesian flow n/a G.P.M. n/a P.S.I.
Water temperature n/a °F Quality n/a

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Hackworth Drilling, Inc. Contractor
Address P.O. Box 850 Contractor
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1395
Signed George M Adkins By driller performing actual drilling on site or contractor
Date 4/1/98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627