WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 72021
Permit No. 63955
Basin 108

NOTICE OF INTENT NO. 37766

1. OWNER Butch Perri
MAILING ADDRESS 73 East Cremeti Lane
Yerington, NV

ADDRESS AT WELL LOCATION 73 East Cremeti Lane
Yerington, NV

2. LOCATION ~~SW~~ NE 1/4 NW 1/4 Sec. 36 T 13N N/S R 25E E Lyon County
PERMIT NO. 63955 Issued by Water Resources
12-151-09 Parcel No.
Peri Ranch Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [X] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	6	6
Brown clay		6	8	2
Fine brown sand		8	10	2
Multi-colored gravels & fine brown sand		10	47	37
Black & white grainte broken med hard		47	55	8
Multi-colored gravels w/ fine brown sand		55	73	18
Brown fractured gravel w/ fine brown sand.		73	79	6
Multi colored large gravels w/ fine brown sand		79	123	44
Blue, black, white granite hard		123	125	2
N 38 57.048				
W 119 08.160 WGS 84				
REVISED 11/13/06				
N 38.950894				
W 119.135021 NAD27				

Date started 4/17/1998 , 19__
Date completed 4/21/1998 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [X] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30 HP PUMP	260	53	4

8. WELL CONSTRUCTION
Depth Drilled 125 Feet Depth Cased 125 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
15	Inches	0	Feet	125	Feet
	inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10 3/4		.250	+2	125

Perforations:
Type perforation Johnson Agg Screen
Size perforation .050 Slot
From 125 feet to 85 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 53
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 125 feet to 53 feet

9. WATER LEVEL
Static water level 12 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A.S.A.P. Pump & Well Service LLC Contractor
Address PO Box 60130 Contractor
Reno, NV 89056
Nevada contractor's license number issued by the State Contractor's Board 35387C
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1509
Signed [signature] By driller performing actual drilling on-site or contractor
Date 11/13/2006

2006 NOV 14 AM 10:54

USE ADDITIONAL SHEETS IF NECESSARY

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 72021
Permit No. 65278
Basin 108

SECTION 36 BADD

NOTICE OF INTENT NO. 37766

1. OWNER Butch Peri
MAILING ADDRESS 73 E Cremeti Lane
Yerington, NV

ADDRESS AT WELL LOCATION 73 E. Cremeti Lane
Yerington, NV

2. LOCATION NE ¼ SW ¼ NW ¼ Sec. ~~31~~ 36 T. 13 N/S R. ~~26~~ 25 EAST Lyon County
PERMIT NO. 65955 Issued by Water Resources | 12-151-09 Parcel No. | Peri Ranch Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	6	6
Brown clay		6	8	2
Fine Brown sand		8	10	2
Multi colored gravels & fine brown sand		10	47	37
Black & white granite broken med hard		47	55	8
Multi colored gravels w/fine brown sand		55	73	18
Brown fractured gravel w/fine brown sand		73	79	6
Multi colored large gravels w/fine brown sand	X	79	123	44
Blue, black, white granite hard		123	125	2
T.D. 125'				

RECEIVED 98 MAY 11 AM 10:27 STATE ENGINEER'S OFFICE

Date started April 17, 19 98
Date completed April 21, 19 98

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30 hp pump	260	53	4

8. WELL CONSTRUCTION
Depth Drilled 125 Feet Depth Cased 125 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
15" Inches	0 Feet	125 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10 3/4		.250	+2	125

Perforations:
Type perforation Johnson Agg Screen
Size perforation .050 slot
From 125 feet to 85 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 53
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 125 feet to 53 feet

9. WATER LEVEL
Static water level 12 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.S.A.P. Pump & Well Service Inc. (Contractor)
Address P.O. Box 60130 (Contractor)
Reno, Nevada 89506

Nevada contractor's license number issued by the State Contractor's Board 35387-A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1509

Signed Larry Welch (By driller performing actual drilling on site or contractor)
Date May 2, 1998

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627