

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37764

1. OWNER David Peri ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 18 Maple Drive 94 Butte Way
Yerington, Nevada Yerington, Nevada
 2. LOCATION NE $\frac{1}{4}$ SE $\frac{1}{4}$ Sec. 4 T. 14 S. R. 25 EAST LYON County
 PERMIT NO. 14-191-03 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown clay		0	5	5
Multi colored course sand		5	20	15
Multi colored course sand & gravels		20	55	35
Brown clay		55	75	20
Brown clay w/multi colored gravels		75	85	10
Multi colored course sand & gravels	X	85	107	22
Brown clay		107	120	13
T.D. 120'				

8. WELL CONSTRUCTION
 Depth Drilled 120 Feet Depth Cased 120 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 5/8 Inches 0 Feet 70 Feet
10 5/8 Inches 70 Feet 120 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.9	.188	+1 1/2	120

Perforations:
 Type perforation Factory sawed
 Size perforation 3/32 x 3
 From 8.6 feet to 1.00 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 120 feet to 50 feet

Date started April 22 1998
 Date completed April 23 1998

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+		2 hours

9. WATER LEVEL
 Static water level 30' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A.S.A.P. Pump & Well Service Inc. Contractor
 Address P.O. Box 60130 Contractor
Reno, Nevada 89506
 Nevada contractor's license number issued by the State Contractor's Board 35387-A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2066
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date May 2, 1998