


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17742

1. OWNER Linda and Roger Lavoise ADDRESS AT WELL LOCATION 2791 S. Papaya
 MAILING ADDRESS 2791 S. Papaya
Pahrump, NV 89048

2. LOCATION SW 1/4 SE 1/4 Sec. 28 T 20S N/S R 53E E Nye County
 PERMIT NO. 40-411-08 Calvada Valley
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
brown clay		0	8	8
grey clay		8	12	4
brown clay		12	14	2
light brown calache		14	21	7
brown clay		21	38	17
brown clay		38	57	19
grey calache	x	57	75	18
light brown calache	x	75	78	3
brown clay	x	78	87	9
grey calache	x	87	89	2
brown calache	x	89	110	21
grey calache	x	110	113	3
brown clay	x	113	121	8
brown clay	x	121	140	19

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
 From 11 Inches To 0 Feet 140 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	140


Perforations:
 Type perforation saw cut
 Size perforation .188

From 100 feet to 140 feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 140 feet

9. WATER LEVEL
 Static water level 57 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good



Date started 7/21/98 19____
 Date completed 7/21/98 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>.5</u>	<u>na</u>	<u>.50</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc. Contractor
 Address 2301 Winery Road, Suite 2 Contractor
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board 40277
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086

Signed [Signature]
 By driller performing actual drilling on-site or contractor
 Date 7.27.98

