

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. **72070**  
 Permit No. **122**  
 Basin **122**

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **17743**

1. OWNER **Tom Gascoligne** ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS **5891 N. Nopah Vista** **5891 N. Nopah Vista**  
**Pahrump, NV 89048**

2. LOCATION **NW 1/4 NW 1/4 Sec. 15 T 19S** N/S R **53E** E **Nye** County  
 PERMIT NO. **29-221-12** **The Country Place II**  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown sandy loam		0	14	14
dark brown sandy loam		14	22	8
darkbrown sandy loam		22	47	25
brown calache		47	68	21
brown calache, rock, gravel		68	74	6
grey calache, rock, gravel		74	76	2
brown sandy loam, gravel		76	89	13
brown sandy loam, gravel		89	110	21
brown calache and gravel	x	110	121	11
brown sandy loam, gravel	x	121	142	21
See next line	x	142	162	20
brown caalche rock and gravel				
brown sandy loam and gravel	x	162	166	4
brown sandy loam and gravel	x	166	170	4
See next line	x	170	180	10
brown sandy loam and rock, gravel				

8. WELL CONSTRUCTION  
 Depth Drilled **180** Feet Depth Cased **180** Feet

HOLE DIAMETER (BIT SIZE)  
 From **11** Inches To **0** Feet **180** Feet  
 Inches Feet Feet Feet  
 Inches Feet Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	180

Perforations:  
 Type perforation **saw cut**  
 Size perforation **.188**

From **140** feet to **180** feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal **50**  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From **50** feet to **180** feet

9. WATER LEVEL  
 Static water level **110** feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature **cold** °F Quality **good**

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Strickland Construction Co., Inc.**  
 Contractor  
 Address **2301 Winery Road, Suite 2**  
 Contractor  
**Pahrump, NV 89048**

Nevada contractor's license number issued by the State Contractor's Board **40277**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2086**

Signed **Larry Strickland**  
 By driller performing actual drilling on-site or contractor  
 Date **7.27.98**

Date started **7/15/98**, 19\_\_\_\_  
 Date completed **7/15/98**, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<b>.5</b>	<b>na</b>	<b>.50</b>

