

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

27958  
 NOTICE OF INTENT NO 34466

1. OWNER SILVER OAKS GC ADDRESS AT WELL LOCATION SILVER OAKS GOLF COURSE  
 MAILING ADDRESS Box 2257  
CARSON CITY, NV 89702  
 2. LOCATION NE 1/4 NE 1/4 Sec 6 T. 15 S. R. 19 E CARSON County  
 PERMIT NO. SW NONE Parcel No. GOLF COURSE Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other DRIVEN

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
THE 8-INCH CASING WELL HAD BEEN BURIED & WAS FULL OF SAND TO 90 FT. THE AREA AROUND THE CASING HAD BEEN EXCAVATED, SO WE COULD NOT GET OVER THE PIPE. WE WELDED AN 8 FT EXTENSION TO THE OLD PIPE & BACKFILLED AROUND IT & MOVED A MIDWAY MIS ON THE SITE. THE M-15 PULLS 60,000#. WE COULD NOT PULL THE PIPE. WE BLEW THE SAND OUT OF THE PIPE & USING A ROLLER BLADE PERFORATOR PERFORATED THE CASING FROM 2 FT TO 90 FT. RAN TREMIE PIPE TO ~ 88 FT & PUMPED NEAT CEMENT TO SURFACE. PULLED TREMIE & FILLED HOLE TO SURFACE. WE PUMPED 52 SX OF CEMENT INTO THE WELL, 20 MORE THAN SHOULD BE.				
THE 2-INCH & 1/4-INCH HOLES WERE BLOWN CLEAN WITH A SMALL TUBE & THEN CEMENTED TO THE SURFACE. THESE WELLS/PIPES COULD NOT BE PULLED.				

8. WELL CONSTRUCTION  
 Depth Drilled.....Feet Depth Cased.....Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
 \_\_\_\_\_Inches\_\_\_\_\_Feet\_\_\_\_\_Feet  
 \_\_\_\_\_Inches\_\_\_\_\_Feet\_\_\_\_\_Feet  
 \_\_\_\_\_Inches\_\_\_\_\_Feet\_\_\_\_\_Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:  
 Type perforation.....  
 Size perforation.....  
 From.....feet to.....feet  
 From.....feet to.....feet  
 From.....feet to.....feet  
 From.....feet to.....feet  
 From.....feet to.....feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal.....  
 Placement Method:  Pumped  Poured  
 Poured

Gravel Packed:  Yes  No  
 From.....feet to.....feet

Date started..... 6/12 1998  
 Date completed..... 6/18 1998

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL  
 Static water level.....feet below land surface  
 Artesian flow.....G.P.M.....P.S.I.  
 Water temperature.....°F Quality.....

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name NEVADA DRILLING, INC Contractor  
 Address 75 LEWERS CRK RD Contractor  
WASHOE VALLEY, NV 8704  
 Nevada contractor's license number issued by the State Contractor's Board 13697A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790 + 1902  
 Signed Joe Linder  
 by driller performing actual drilling on site or contractor  
 Date 6/26/98