WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 72092
Permit No. 64863
Basin 107

NOTICE OF INTENT NO. 37587

1. OWNER Gerald Simmons
MAILING ADDRESS 90 Jesson Road Yerington Nev. 89447
ADDRESS AT WELL LOCATION 90 Jesson Road Yerington Nev. 89447

2. LOCATION SE ¼ SE ¼ Sec. 26 T. 12 N/S R. 23 E. Lyon County
PERMIT NO. none (Issued by Water Resources) 10-111-25 (Parcel No.) none (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	7	7
Sand + Gravel	yes	7	42	35
Blue Sandy Clay		42	55	13
Gray Sand	yes	55	190	135
Black Clay		190	225	35
~~Black Clay~~				
Coarse Sand	yes	225	232	7
Black Clay		232	262	30
Coarse Sand + Pea Gravel		262	275	13

Date started June 6, 19 98
Date completed June 30, 19 98

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☑ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	25	4 hrs

8. WELL CONSTRUCTION
Depth Drilled 275 Feet Depth Cased 275 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
8	0	240
6	240	275

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5 5/8		188	0	240
6 5/8		188	240	275

Perforations:
Type perforation Factory saw slott
Size perforation 3/32 x 3
From feet to feet
From 240 feet to 275 feet
From 240 feet to 275 feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50 ft
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☑ No
From feet to feet

9. WATER LEVEL
Static water level 5 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Edward Miller
Address P.O. Box 92 Smith Nev. 89430 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 32166
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718
Signed Edward Miller (By driller performing actual drilling on site or contractor)
Date July 1 1998

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627