WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 72097
Permit No. 19015
Basin 153

NOTICE OF INTENT NO. 32373

1. OWNER WALTER PLASKETT
MAILING ADDRESS BOX 10
EUREKA NEV. 89316.

[redacted]

2. LOCATION NE ¼ NW ¼ Sec 5 T 21 N R 54 E EUREKA County
PERMIT NO. 19015 Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		TOP	2	2
SAND & GRAVEL		2	7	5
CLAY		7	50	43
SAND & GRAVEL		50	60	10
CLAY		60	124	64
SAND & GRAVEL	14	124	138	14
CLAY		138	140	2
SAND & GRAVEL	3	140	143	3
CLAY		143	157	12
SAND & GRAVEL	7	157	164	7
CLAY		164	217	53
SAND & GRAVEL	2	217	220	2
CLAY		220	231	11
SAND & GRAVEL	3	231	234	3
CLAY		234	243	9
SAND & GRAVEL	3	243	246	3
SAND & GRAVEL & CLAY	14	246	260	14
CLAY		260	264	4
SAND & GRAVEL	24	264	288	24
CLAY & GRAVEL		288	292	4
CEMENTED SAND & GRAVEL WITH SOME SANDSTONE LAYERS AND SOME SOFT CLAYS		292	339	47
plugged by well log 195841				

Date started 5-20-98, 19
Date completed 6-3-98, 19

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 339 Feet Depth Cased 339 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
30	TOP	339

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16		¼	TOP	299
10		¼	299	339

Perforations:
Type perforation ROSCO MOSS
Size perforation ⅛"
From 120 feet to 160 feet
From 215 feet to 295 feet
From 299 feet to 339 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From TOP feet to 50 feet

9. WATER LEVEL
Static water level 64' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WALTER PLASKETT (Contractor)
Address BOX 10 (Contractor)
EUREKA, NEV. 89316
Nevada contractor's license number issued by the State Contractor's Board 11882
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 635
Signed James E. Roth (By driller performing actual drilling on site or contractor)
Date 6-28-98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627