

OFFICE USE ONLY  
Log No. 72110  
Permit No. I  
Basin. I 137B  
NOTICE OF INTENT NO. 32838

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Round Mountain Gold ADDRESS AT WELL LOCATION MINESUIT - e  
MAILING ADDRESS PO Box 480  
Round Mountain, NV 89045  
2. LOCATION NW 1/4 SW 1/4 Sec. 19 T 10 N/R 44 E Nye County  
PERMIT NO. M.O. 671A Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Pump 20 SK. CNT - Mixed 5.5' to 1 SK. CNT. Pump into both 1" columns AT SAME TIME. MAINTAINED 200 PSI cut off AT surface.				

8. WELL CONSTRUCTION  
Depth Drilled 710 Feet Depth Cased 20 Feet  
HOLE DIAMETER (BIT SIZE)  
From 12 1/4 Inches To 0 Feet 20 Feet  
6 1/4 Inches 20 Feet 705 Feet  
Inches Feet Feet  
CASING SCHEDULE DUAL  
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)  
8 5/8 16.79 1/8 +1 20  
1" sch. 80 +1 582  
sch. 80 +1 520  
Perforations:  
Type perforation 10 slot/in  
Size perforation 220  
From 510 feet to 520 feet  
From 522 feet to 582 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
Surface Seal:  Yes  No Seal Type:  
Depth of Seal 570'  Neat Cement  
Placement Method:  Pumped 50-500 hole plug  Cement Grout  
 Poured 570-525 gravel  Concrete Grout  
525-575 plug it  
Gravel Packed:  Yes  No 600-705 neat cnt.  
From 50 feet to 200 feet

9. WATER LEVEL  
Static water level: \_\_\_\_\_ feet below land surface  
Artesian flow: Not Available G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature: \_\_\_\_\_ °F Quality: \_\_\_\_\_

Date started 4-30, 1998  
Date completed 4-30, 1998

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Waytek Drilling Contractor  
Address 2220 Stone Dr Reno NV 89511 Contractor  
Nevada contractor's license number issued by the State Contractor's Board 024521  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442  
Signed Lesley By driller performing actual drilling on site or contractor  
Date 5-8-98

RECEIVED  
03 MAY 12 AM 10:36  
STATE ENGINEERING OFFICE