WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

P-1 / 7

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 72112
Permit No. 137B
Basin

NOTICE OF INTENT NO. 32830

1. OWNER Round Mountain Gold
MAILING ADDRESS PO Box 480
Round Mountain, NV 89045

ADDRESS AT WELL LOCATION
Minesite

2. LOCATION NW ¼ SW ¼ Sec. 19 T. 10 N/S R. 44 E. Nye County
PERMIT NO. M0671A (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Pump 20 sks cmt -				
Mixed 5.5 gal to 1 sk. cmt.				
Pump into both 1" columns				
At same time.				
Maintained 200 psi				
Cut off at surface.				

RECEIVED
98 MAY 12 AM 10:36
STATE ENGINEER'S OFFICE

Date started 4-30, 1998
Date completed 4-30, 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 710 Feet Depth Cased 20 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	20 Feet
6¼ Inches	20 Feet	705 Feet
Inches	Feet	Feet

CASING SCHEDULE DUAL

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	[redacted]	[redacted]	+1	20
[redacted]			+1	[redacted]
[redacted]				

Perforations:
Type perforation 10 slot/in
Size perforation .020
From 510 feet to 520 feet
From [redacted] feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped 50-500 hole plug ☐ Poured 510-525 gravel 525-565 plug it
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
600-705 Neat cmt.

Gravel Packed: ☒ Yes ☐ No
From 500 525 [redacted] feet

9. WATER LEVEL
Static water level ? feet below land surface
Artesian flow Not Available G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Woyten Drilling (Contractor)
Address 2220 Stewart Dr (Contractor)
Reno NV 89511
Nevada contractor's license number issued by the State Contractor's Board 024521
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442
Signed Leo Woyten (By driller performing actual drilling on site or contractor)
Date 5-8-98

USE ADDITIONAL SHEETS IF NECESSARY

Rev. 1/91 (01-627)