WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 72139
Permit No.
Basin 49

NOTICE OF INTENT NO. 15797

1. OWNER Al Park Petroleum
MAILING ADDRESS 1600 Idaho Street Elko NV
ADDRESS AT WELL LOCATION 1600 Idaho St Elko NV

2. LOCATION SE ¼ SW ¼ Sec. 11 T. 34 N/S R. 55 E. Elko County
PERMIT NO. (Issued by Water Resources) 001-590-003 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE MW-2
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT/SANDY GRAVEL		0	5	5
GRAVELLY SAND		5	10	5
SANDY GRAVEL		10	24	14
CLAYEY GRAVEL		24	26	2
SANDY GRAVEL		26	32	6
SILTY SAND		32	50	18

RECEIVED 98 AUG 11 AM 11:02 NEVADA DIVISION OF WATER RESOURCES

Date started FEB 11, 19 98
Date completed FEB 11, 19 98

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 50 Feet Depth Cased 50 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	50 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.64	0.154	0	50

Perforations:
Type perforation FACTORY SLOT
Size perforation 0.020
From 30 feet to 50 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-26/26-28' BENTONITE
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 28 feet to 50 feet

9. WATER LEVEL
Static water level 40.65 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name THOMAS HIGH (CONVERSE CONS) Contractor
Address 731 Pilot Rd Ste H Contractor
LAS VEGAS NV 89119
Nevada contractor's license number issued by the State Contractor's Board 0034757
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1869
Signed (By driller performing actual drilling on site or contractor)
Date 7/10/98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627