WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 72144
Permit No.
Basin 212

NOTICE OF INTENT NO. 15700

1. OWNER AGRA c/o DUNRITE CONSTRUCTION
MAILING ADDRESS 12 B SUNSET WAY STE 218 HENDERSON NV 89014
ADDRESS AT WELL LOCATION 1250 W. SUNSET RD HENDERSON NV 89014

2. LOCATION SE ¼ NW ¼ Sec. 3 T. 22 N(S) R 62 E. CLARK County
PERMIT NO. (Issued by Water Resources) Parcel No. 178-03-210-001 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other AUGER

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| SANDY GRAVEL/BOULDERS | | 0 | 35 | 35 |

Date started MARCH 10, 1998
Date completed MARCH 10, 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 35 Feet Depth Cased 35 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From Feet | To Feet |
|---|---|---|
| 8 | 0 | 35 |
| | | |
| | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2.375 | 0.64 | 0.154 | 0 | 35 |
| | | | | |

Perforations:
Type perforation FACTORY SLOT
Size perforation 0.020
From 15 feet to 35 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-10/10-12' BENTONITE
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 12 feet to 35 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name THOMAS HIGH (CONVERSE CONS) Contractor
Address 731 Pilot Rd Ste H Contractor
LAS VEGAS NV 89119
Nevada contractor's license number issued by the State Contractor's Board 0034757
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 41869
Signed
By driller performing actual drilling on site or contractor
Date 7/10/98

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627