


STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Log No. **72155**

Permit No.

Basin **162**



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **18038**

1. OWNER **Chris and Aimee Capagli** ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS **3260 W. Retread** **3260 W. Retread**
Pahrump, NV 89048

2. LOCATION **NE 1/4 SE 1/4 Sec. 13 T 20S** N/S **R 52E** E **Nye** County
 PERMIT NO. **28-643-03** Parcel No. _____ Subdivision Name **Charleston Park Ranchos**
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown clay		0	7	7
white clay		7	9	2
grey calache		9	12	3
brown clay		12	30	18
grey clay		30	52	22
light brown clay	x	52	65	13
brown clay	x	65	81	16
brown clay	x	81	103	22
brown clay	x	103	121	18
grey calache	x	121	123	2
grey clay	x	123	125	2
brown calache	x	125	140	15

8. WELL CONSTRUCTION
 Depth Drilled **140** Feet Depth Cased **140** Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
11 Inches **0** Feet **140** Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	140


Perforations:
 Type perforation **sawcut**
 Size perforation **.188**
 From **110** feet to **140** feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal **50** Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From **50** feet to **140** feet

9. WATER LEVEL
 Static water level **52** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature **cold** °F Quality **good**

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Strickland Construction Co., Inc.** Contractor
 Address **2301 Winery Road, Suite 2** Contractor
Pahrump, NV 89048
 Nevada contractor's license number issued by the State Contractor's Board **40277**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2086**
 Signed *[Signature]*
 By driller performing actual drilling on-site or contractor
 Date **7-15-98**



Date started **7/13/98**, 19____
 Date completed **7/13/98**, 19____

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		Time (Hours)
	G.P.M.	Draw Down (Feet Below Static)	
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	.5	na	.50