WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 72179
Permit No.
Basin 179

NOTICE OF INTENT NO. 15709

1. OWNER City of Ely Public Works
MAILING ADDRESS 501 Mill Street
Ely, NV 89301

ADDRESS AT WELL LOCATION 11th Avenue D:
Ely, NV 89315

2. LOCATION NW ¼ NE ¼ Sec. 15 T. 16 N/S R. 63 E White Pine County
PERMIT NO. Issued by Water Resources | Parcel No. 2-028-12 | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [X] Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty Clay		0'	50'	50'
Gravel + Cobbles	47'	50'	64'	14'

RECEIVED
98 AUG 14 AM 11:02
STATE ENGINEER'S OFFICE

AUG 3 1998

Date started 4/16, 19 98
Date completed 4/16, 19 98

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 64 Feet Depth Cased 64 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
9 Inches	0 Feet	64 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.70	0.25	44	64
2.375	0.70	0.15	0	44

Perforations:
Type perforation Slotted PVC
Size perforation 0.020"
From 44 feet to 64 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 3'
Placement Method: [ ] Pumped [X] Poured 3-5' bentonite seal
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 5 feet to 64 feet

9. WATER LEVEL
Static water level ~47' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Thomas High
Contractor
Address 731 Pilot Road, Suite H
Contractor
Las Vegas, NV 89119
Nevada contractor's license number issued by the State Contractor's Board 0034757
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1689
Signed
By driller performing actual drilling on site or contractor
Date 7-29-98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627