

Log No. 72182
 Permit No. _____
 Basin 84

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37765

1. OWNER Bruce Cody Cote ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 5851 Whiskey Springs 5851 Whiskey Springs
Reno, Nevada Reno, Nv
 2. LOCATION SW 1/4 SW 1/4 Sec. 3 T 22 N/S R 21 EAST WASHOE County
 PERMIT NO. _____ Parcel No. 77-340-34 Subdivision Name Washoe Valley Water Service, Inc. 1-3

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Multi colored volcanic rock		382	460	78
Multi colored volcanic rock w/light brown clay		460	475	15
Multi colored volcanic rock		475	525	50
Light brown clay w/multi colored volcanic rock	X	525	550	25
Multi colored volcanic rock	X	550	650	100
Multi colored volcanic rock w/brownish red clay	X	650	700	15
T.D. 700'				

8. WELL CONSTRUCTION
 Depth Drilled 700 Feet Depth Cased 675 Feet
 HOLE DIAMETER (BIT SIZE)
 From 6 1/8 Inches 382 Feet 675 Feet
 To _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5"	6.56	.188	274	675

Perforations:
 Type perforation Factory sawed
 Size perforation 3/32 x 3
 From 535 feet to 675 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal In place Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 200 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A.S.A.P. Pump & Well Service Inc. Contractor
 Address P.O. Box 60130 Contractor
Reno, Nevada 89506
 Nevada contractor's license number issued by the State Contractor's Board 35387-A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2066
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date May 18, 1998

Date started April 24 19 98
 Date completed April 28 19 98

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>6.5</u>		<u>8 hrs.</u>