

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 72209
 Permit No. _____
 Basin. 104

NOTICE OF INTENT NO. 9880

1. OWNER Dan Wheeler ADDRESS AT WELL LOCATION 4684 dd Clear Creek Rd.
 MAILING ADDRESS P.O. Box 6265 Incline Village NV. 89450 Carson City NV. 89702
 2. LOCATION SW 1/4 SW 1/4 Sec. 35 T. 15 S. R. 19 E Carson County
 PERMIT NO. 7-042-19 Parcel No. _____ Subdivision Name Clear Creek

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other ✓

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Coarse DG Sands</u>		<u>0</u>	<u>63</u>	<u>63</u>
<u>Decomposed Granite coarse & Rusty</u>		<u>63</u>	<u>143</u>	<u>80</u>
<u>Medium Granite Grayish in color</u>		<u>143</u>	<u>180</u>	<u>37</u>
<u>Fractured Granite Carrying Water</u>	<u>xxx</u>	<u>180</u>	<u>220</u>	<u>40</u>

8. WELL CONSTRUCTION
 Depth Drilled 220 Feet Depth Cased 220 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 3/4 Inches To 0 Feet 220 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>220</u>

Perforations:
 Type perforation Mill Slot
 Size perforation 3 x 3/32
 From 200 feet to 220 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 220 feet

Date started 4-23, 19 98
 Date completed 4-27, 19 98

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20-25</u>	<u>6.5</u>	<u>3 HRS</u>

9. WATER LEVEL
 Static water level 110 feet below land surface
 Artesian flow _____ G.P.M. 20-25 P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Capital City Well Drilling Contractor
 Address 20 Kit Kat DR. Contractor
Carson City NV 89706
 Nevada contractor's license number issued by the State Contractor's Board 41775
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
 Signed Michael D. Hood
 By driller performing actual drilling on site or contractor
 Date 4-27-98