

Log No. 72218
 Permit No. 84
 Basin _____

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37762

1. OWNER Fred Mister ADDRESS AT WELL LOCATION 4700 Hidden Creek Road
 MAILING ADDRESS 4700 Hidden Creek Road Reno, NV 89510 Reno, NV

2. LOCATION SW 1/4 NW 1/4 Sec. 12 T. 22 R/S R 21 EAST WASHOE County
 PERMIT NO. 077-110-24 Palomino v. Suit 12-2-1-1 par. 3
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Green & black volcanic rock		445	470	25
Green & Red volcanic rock w/gray clay		470	490	20
Green volcanic rock		490	505	15
White clay w/gray & green volcanic rock		505	515	10
Green & red volcanic rock w/gray clay		515	520	5
Green volcanic rock		520	530	10
Green & red volcanic rock w/brown clay		530	540	10
Green volcanic rock fractured		540	560	20
Green & brown volcanic rock	X	560	630	70
Green volcanic rock fractured	X	630	660	30
Multi colored volcanic rock w/gray clay	X	660	680	20
Red volcanic rock		680	697	17
T.D. 697'				
<i>Deepening of 6849'</i>				

8. WELL CONSTRUCTION

Depth Drilled 697 Feet Depth Cased 697 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>6-1/8</u> Inches	<u>445</u> Feet <u>697</u> Feet
_____ Inches	_____ Feet _____ Feet
_____ Inches	_____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>5"</u>	<u>6.56</u>	<u>.188</u>	<u>418</u>	<u>697</u>
_____	_____	_____	_____	_____

Perforations:
 Type perforation Factory Sawn
 Size perforation 3/32 x 3

From	To
<u>6.60</u> feet to <u>6.80</u> feet	
<u>5.80</u> feet to <u>6.20</u> feet	
_____ feet to _____ feet	
_____ feet to _____ feet	

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal In place

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From _____ feet to _____ feet

Date started June 3, 1998.
 Date completed June 5, 1998.

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>10</u>		<u>3 hrs.</u>

9. WATER LEVEL

Static water level 50' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.S.A.P. Pump & Well Service Inc. Contractor
 Address P.O. Box 60130 Contractor
Reno, NV 89506

Nevada contractor's license number issued by the State Contractor's Board 35387-A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2066

Signed [Signature] By driller performing actual drilling on site or contractor
 Date 6-9-98