WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 72233
Permit No.
Basin 105

NOTICE OF INTENT NO. 38834

1. OWNER Wayne Gusselman
MAILING ADDRESS Gardnerville NV 89410
ADDRESS AT WELL LOCATION 640 Thoroughbred Ave Gardnerville NV 89410

2. LOCATION NE ¼ NE ¼ Sec. 25 T. 12 N/S R. 20 E. Douglas County
PERMIT NO. Issued by Water Resources | 29-102-01 Parcel No. | Riverstroth Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Hard Pan Clay		0	3	3
Course ¼ Gravels		3	21	18
Brown Clay		21	43	22
Fractured obsidian (Hard) Gravels w/clay Seams		43	87	44
Cemented Gravels Clay Stratas and Small Volcanic Gravels		87	130	43
Fractured (Hard) Volcanic Rock		130	225	95
Brown Clay Volcanic Gravels		225	265	40
Fractured Gravels 7-10 gallons	XX	265	280	15
Fractured Volcanic Sand and Gravels 20 + gallons	XXX	280	310	30

RECEIVED JUL 30 AM 9:14 ENGINEER'S OFFICE

Date started 7-24, 1998
Date completed 7-28, 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20-22	50	3 HRS.

8. WELL CONSTRUCTION
Depth Drilled 310 Feet Depth Cased 310 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 3/4 Inches		0 Feet	310 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	310

Perforations:
Type perforation Mill Slot.
Size perforation 3x3/32
From 270 feet to 310 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 55 feet to 310 feet

9. WATER LEVEL
Static water level 180-200 feet below land surface
Artesian flow G.P.M. 20-22 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Capital City Well Drilling Contractor
Address 20 Kit Kat DR. Contractor
Carson City NV. 89706
Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L Hall
By driller performing actual drilling on site or contractor
Date 7-28-98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627