

WELL DRILLER'S REPORT

Log No. 72234
 Permit No. _____
 Basin. 874

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37853

1. OWNER JEFF & DAWN HILL ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 521 Crampton Street Lot 15, Wilcox Ranch Road
Reno, Nevada 89502 Reno, Nevada 89510
 2. LOCATION NW 1/4 SE 1/4 Sec 9 T 21N N/S R 22 E Washoe County
 PERMIT NO. 077-420-04 Parcel No. Palomino Valley Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown clay		0	2	2
Brown volcanic rock		2	27	25
Reddish brown volcanic rock		27	69	42
Multi-color clays		69	91	22
Gray volcanic rock		91	98	7
Soft zone (app 3 GPM)	X	98	99	1
Gray volcanic rock		99	178	79
Fracture (app 3 GPM)	X	178	179	1
Gray volcanic rock (weathered)		179	218	39
Reddish brown volcanic rock		218	238	20
Fracture (app 2 GPM)	X	238	239	1
Brown & black volcanic rock w/clay streaks		239	302	63
Fracture rock	X	302	335	33
Brown & black volcanic rock w/clay streaks		335	375	40

8. WELL CONSTRUCTION
 Depth Drilled 375 Feet Depth Cased 375 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 100 Feet
8 5/8 Inches 100 Feet 375 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	375

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 195 feet to 215 feet
 From 335 feet to 355 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 feet Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 375 feet

9. WATER LEVEL
 Static water level 50 feet below land surface
 Artesian flow _____ G.P.M. 20 P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board 0022549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date July 27, 1998

Date started 7-20-98, 19____
 Date completed 7-23-98, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20</u>		