



Log No. 72235
 Permit No. _____
 Basin. 92A

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 39787

1. OWNER J & L Builders ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 10900 Red Rock Road 9675 Red Rock Road
Reno, NV 89506 Reno, NV 89506
 2. LOCATION NE 1/4 SE 1/4 Sec. 35 T. 21 S/R 18 EAST WASHOE County
 PERMIT NO. 087-340-13 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Install 3/8 gravel to 180' to hold cement, install trimie pipe to 180' & pump approx 1800 lbs of neat cement in well to seal upper perforation, set up, drill out cement plug, circulate out 3/8 gravel from 180 to 525'. Develop with air @ 20 g.p.m. water was gray clay, build up tool to fish out 5" liner pulled with approx 60,000 lbs Pull back liner, will not move circulate mud from inside liner to around outside- trip in spear & pull on liner with 60,000 lbs of pull back liner still won't move. Install trimie pipe to 525' & pump approx 4400 lbs of neat cement in well remove trimie, perforate casing from 80' to 150' 4 rows. Develop approx 12 gpm from 180 for approx 4 hrs. to clean & develop with air.				

8. WELL CONSTRUCTION
 Depth Drilled _____ Feet Depth Cased 525 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
 Inches _____ Feet _____ Feet
 Inches _____ Feet _____ Feet
 Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
 Type perforation Air Perforator
 Size perforation 1/4 x 1
 From 80 feet to 150 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal In place Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

Date started June 23, 1998
 Date completed June 30, 1998

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>12</u>		<u>3 hrs.</u>	

9. WATER LEVEL
 Static water level 60' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.S.A.P. Pump & Well Service Inc. Contractor
 Address P.O. Box 60130 Contractor
Reno, NV 89506

Nevada contractor's license number issued by the State Contractor's Board 35387-A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2066
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date July 20, 1998