PPW-94

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 72237
Permit No.
Basin G1

NOTICE OF INTENT NO. 39223

1. OWNER BARRICK GOLDSTRIKE
MAILING ADDRESS P.O. BOX 29
ELKO, NV 89803

ADDRESS AT WELL LOCATION BARRICK GOLDSTRIKE MINE SITE

2. LOCATION SW ¼ SE ¼ Sec 19 T 36 (N)S R 50 E EUREKA County
PERMIT NO. 55140 (Issued by Water Resources) | N/A (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[X] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [X] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GRANITE/BROWN ROCK		0	100	100
GRANITE WITH CLAY		100	300	200
GRANITE/BLACK ROCK		300	340	40
GREY CLAY		340	395	55
GRANITE/CLAY		395	435	40
GRANITE/BLACK ROCK		435	600	165
CLAY/GREY		600	650	50
HOLE PLUG WAS INSTALLED FROM 615' TO 605'				

Date started JULY 13, 1998
Date completed JULY 14, 1998

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
26	251.1	1 HOUR

8. WELL CONSTRUCTION
Depth Drilled 650 Feet Depth Cased 638 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
20.50 Inches		0 Feet	32 Feet
12.250 Inches		32 Feet	650 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14	54.57	.375	0	32
6.625	17.02	.250	+2	595
1.660	2.27	.140	+2	638

Perforations: 6.625", LOUVERED, 1.660", DRILLED
Type perforation HOLE, 0.125"
Size perforation 0.125
From 60 feet to 595 feet
From 618 feet to 638 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout
Gravel Packed: [X] Yes [ ] No 6": 50'-650' 1.5": 615'-650'
From feet to feet

9. WATER LEVEL
Static water level 240.2 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 95 °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LANG EXPLORATORY DRILLING (Contractor)
Address P.O. BOX 5279 (Contractor)
ELKO, NV 89802
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2085
Signed Dan Kohlman (By driller performing actual drilling on site or contractor)
Date 7-14-98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627

B.S.C