



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 33071

1. OWNER Cove Meadows Ranch ADDRESS AT WELL LOCATION 10 miles NW of McGill  
 MAILING ADDRESS Box 1030 Nevada (Formerly Lindley Ranch)  
McGill, NV 89318

2. LOCATION SE 1/4 SE 1/4 Sec. 28 T. 19 N/SR. 63 E White Pine County  
 PERMIT NO. 21663 & 30248 Waiver No. R-323 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_  
Issued by Water Resources

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	10	10
Gravel & Sand		10	25	15
Clay & Some Rock		25	30	5
Oxidized Gravel & Sand	x	30	40	10
Gravel Blue Clay & Sand		40	55	15
Gravel & Sand		55	60	5
Brown Clay & Gravel		60	65	5
Water Gravel & Sand	x	65	75	10
Brown Clay & Gravel		75	90	15
Water Gravel & Sand	x	90	100	10
Brown Clay Gravel & Sand		100	115	15
Water Gravel & Sand	x	115	125	10
Clay Gravel & Sand		125	130	5
Brown Clay & Gravel		130	160	30

8. WELL CONSTRUCTION  
 Depth Drilled 160 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
10 Inches 0 Feet 160 Feet  
20 Inches 0 Feet 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16	42.05	.250	0	140

Perforations: Factory  
 Type perforation \_\_\_\_\_  
 Size perforation 1/8" x 2 1/2" 16 rows  
 From 30 feet to 130 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 30' Waiver No. R-323  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 30 feet to 140 feet

9. WATER LEVEL  
 Static water level 8 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality Good

Date started June 23, 19 98  
 Date completed June 29, 19 98

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10" Drive Line	1,400	22	4
Turbine			

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Christiansen Drilling, Inc. Contractor  
 Address 557 Ely Avenue Contractor  
Ely, Nevada 89301  
 Nevada contractor's license number 14790  
 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the 1793  
 Division of Water Resources, the on-site driller.  
 Signed Rich Lurie By Jerald D. Christiansen  
 By driller performing actual drilling on site or contractor  
 Date July 28, 1998

RECEIVED  
 28 JUL 31 AM 10:45  
 STATE ENGINEERS OFFICE

*plugged by log 117638  
 replaced by log 117619*