

OFFICE USE ONLY
Log No. 12246
Permit No. 104
Basin 104

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34653

1. OWNER J & B ALEXANDER ADDRESS AT WELL LOCATION 93 JEFFREY PINE LN
MAILING ADDRESS 93 JEFFREY PINE LN CARSON CITY, NV 89105
2. LOCATION NE 1/4 NW 1/4 Sec 4 T. 14 N. S. R. 19 E. CARSON CITY County
PERMIT NO. 15 030 0907 Subdivision Name NA

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SEE ATTACHMENT				
SEE LOG # 153017 & 211022				

8. WELL CONSTRUCTION

Depth Drilled.....Feet Depth Cased.....Feet

HOLE DIAMETER (BIT SIZE)
From 8 Inches To 3 1/2 Feet
Inches.....Feet.....Feet
Inches.....Feet.....Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>		<u>0.156</u>	<u>+1</u>	<u>340</u>

(MILLER LOG)

Perforations:
Type perforation TORCH CUT
Size perforation.....
From.....feet to.....feet
From 200 feet to 240 feet
From.....feet to.....feet
From 320 feet to 340 feet
From.....feet to.....feet
(MILLER LOG)

Surface Seal: Yes No Seal Type:
Depth of Seal..... Neat Cement
Placement Method: Pumped Cement Grout
(SEE MILLER LOG) Concrete Grout
Gravel Packed: Yes No
From.....feet to.....feet

Date started 7-1-98, 19.....
Date completed 7-2-98, 19.....

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL

Static water level 60 feet below land surface
Artesian flow.....G.P.M. P.S.I.
Water temperature.....°F Quality.....

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.


Name NEVADA DRILLING, INC Contractor
Address 75 LEWERS CRK RD Contractor
WASHOE VALLEY, NV 89704
Nevada contractor's license number 13697A
issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
Signed Joe Reisch
By driller performing actual drilling on site or contractor
Date 7/22/98



75 LEWERS CREEK ROAD • CARSON CITY, NEVADA 89704

Tel/Fax (702) 887-1975

2/2
72246



Plug Well: Jim and Barbara Alexander

NV Lic. No. 13697A
CA Lic. No. 642020

Moved on site

Set up over 6-inch casing on house pad

Ran casing ripper to bottom (340 ft)

Cut four rows of punctures from 140 ft (bottom of seal) to 335 ft

Ran tremie pipe to near bottom

Pumped a 40 sx neat cement mix; no evidence of any sealing.

Let set and check bottom. No cement, hole bottom at 340 ft

Fill bottom of casing with small gravel. Gravel up to 330 ft

Mix a 20 sx neat cement, use CaCl accelerator

Seal hole and casing from hole bottom to 330 ft

Waited 2 hours and checked bottom. Tag cement at 315 ft

Pump 50 sx neat cement mix, fill pipe and hole up to about 218 ft

Pump 50 sx neat cement mix, fill hole and pipe up to about 10 ft. Let set and bring cement up to about 5 ft below ground level

Client cut casing off and filled and compacted the hole